

Project: Dublin CC Accessibility Audits

Job No: 23399



Use Type: Public Park

Auditor: N Williamson

Date of Audit: 27/03/2007

Capita Ref: 057

Name: Dodder / Milltown Road

Address: South East

Section 1: Approach Routes & Street Furniture

REF	QUESTION	Y/N	LOCATION	RECOMMENDATION	QTY	PHOTO REF	PRIORITY	COSTS
1.1	Is the park easy to find?	No		The park is quite difficult to find. However, it would appear that the park is only used by local who will have knowledge of its locations. No recommendation is being made to provide directional signage in this instance.				€0
1.2	Is the park within convenient walking distance of: Public Highway, Public Transport, Car Parking?	Yes						

1.3	Is the surrounding approach routes level?	No	<p>There is currently no level access to the park from the adjacent car park. Provide level access from this area to the park to assist wheelchair users wishing to use the park.</p> <p>Also, there are steep pathways in and around the park at the bridge and at the the river area. Provide handrails to these pathways. If handrails are fitted ensure that they are fitted at a height between 900 – 1100mm from the pavement surface. Generally handrails should:</p> <p>Have an oval or circular profile. (Circular handrail diameter between 40 – 50mm, Oval profile should be 50mm wide and 38mm deep, have rounded edges with a radius of at least 15mm),</p> <p>Be of a suitable finish that contrasts in colour and luminance with the surroundings against which it is seen without being highly reflective,</p> <p>Be easy and comfortable to grip without being cold to touch.</p>	2	3,6,10,11,12	2	€15,000
-----	---	----	--	---	--------------	---	---------

1.4	Are the approach routes minimum 1.8m wide?	Yes
-----	--	-----

1.5	Are approach route surfaces even and slip resistant?	Yes
-----	--	-----

1.6	Do approaches to crossovers have the necessary contrasting tactile surfaces and dropped kerbs?	Yes
-----	--	-----

1.7	Is the approach route to the park entrances clearly signed?	No	The signage at the entrances of the park is unsuitable. Many entrances do not have signage or the existing signage is dated and worn. Provide suitable signage at all entrances offering the opening and closing times etc. The background of the general signboard should be white and the text should be black or dark blue. Please refer to BS 8300 'Table 5' and 'Table 6' and NDA buildings for everyone for full details.	3	1,13	1	€1,000
1.8	Is the approach route to the park suitably lit (if park operates after dark)?	Yes					
1.9	Is the approach route to the park entrances free of hazards such as bollards, litter bins etc?	No	There are hazardous bollards on the approach route. This may present a problem for persons with a visual impairment. Reposition the obstruction out with the access approach. If this is not feasible ensure that any bollards and litterbins etc. contrast in colour and luminance with the surroundings.	1	14	2	€400
1.10	Is there a designated drop-off point close to a park entrance to allow disabled visitors arriving at the park in vehicles to be safely dropped-off? Is it well signed/marked out?	N/A					

Section 2: Car Parking

REF	QUESTION	Y/N	LOCATION	RECOMMENDATION	QTY	PHOTO REF	PRIORITY	COSTS
2.1	Is there accessible car parking within the park or in close proximity of the park for use by disabled visitors?	No	car park	There are no wheelchair accessible parking facilities provided. However there is adequate room for one to be provided in the car park. Accessible parking spaces to be marked out 4.8m x 2.4m with a 1.2m transfer zone to the side and rear. The designated spaces should be positioned as close to the entrance as possible. Suitable high level signage (incorporating the international symbol for access) should accompany the designated space to help limit misuse of the accessible parking space.	1	2	2	€1,500
2.2	Is the accessible car parking space(s) 4.8m long by 2.4m wide with 1.2m side and rear transfer zones (6.0m x 2.4m with 900mm rear transfer zone for parallel parking bays)?	N/A						
2.3	Is the accessible car parking surface smooth, even and free from loose stones?	Yes						
2.4	Is it adequately lit (if park is open after dark)?	Yes						
2.5	Is there a sufficient number of accessible parking bays to meet the requirements of the park (1 space per 25 standard spaces; 3 spaces per 25-50 standard spaces; 5 spaces per 50-100 standard spaces)?	N/A						

Section 3: Park Entrances

REF	QUESTION	Y/N	LOCATION	RECOMMENDATION	QTY	PHOTO REF	PRIORITY	COSTS
3.1	Is the park entrance(s) easy to find, well signed and clearly distinguishable from the façade?	No		refer to 1.7				
3.2	Is there suitable signage to the main entrance(s) of the park indicating what facilities are available to assist visitors with a disability (i.e. accessible routes, parking, toilets etc)?	No		refer to 1.7				
3.3	Is there level access to park entrances?	Yes						
3.4	Are park entrances wide enough for all users (minimum 800mm)?	Yes						
3.5	If operated by the public, are park gate handles/controls easy to use and at a suitable height for use by visitors standing or seated?	Yes						

Section 4: Horizontal Circulation Routes

REF	QUESTION	Y/N	LOCATION	RECOMMENDATION	QTY	PHOTO REF	PRIORITY	COSTS
4.1	Are circulation routes within the park at least 1800mm wide (or have regular 1800mm wide passing zones)?	Yes						

4.2	Are surfaces even and slip resistant?	No	<p>The surface of the pathways in the park may not be suitable for persons using walking aids or wheelchair users. Resurface the access route surface to provide a slip resistant and reasonably smooth surface.</p> <p>Remove the steps on the approaches adjacent to the bridge to allow wheelchair users to access this area.</p> <p>Also, ensure that the car park is linked to the pathways throughout the park</p>	2	7,8,10,11,12	2	€30,000
4.3	Is park signage suitably positioned, sized and with necessary colour/tonal contrast between letters and background? Is there alternative pictorial signage indicating key park features/warnings etc?	No	<p>Directional signage is unsuitable for persons with a visual impairment. Therefore, provide suitable signage offering directions throughout the park. Directional signs should be suitably positioned to allow persons approaching from all directions to see them easily. For medium range location and direction signs the text height should be a minimum of 60mm. The background of the general signboard should be white and the text should be black or dark blue.</p> <p>Please refer to BS 8300 'Table 5 & 6' and also NDA Buildings for Everyone for Details</p>	1		1	€1,000
4.4	Is adequate seating with armrests provided in larger parks?	N/A					
4.5	Does the park allow general movement to all areas; accessible paths, accessible gates, segregation of pedestrians from vehicles?	Yes					

4.6	Are circulation routes kept free of debris, foliage, overgrown plants/shrubs etc?	No	Ensure that all pathways are kept clear of debris/mud/overgrown grass etc to assist persons with visual and mobility impairments.	1	4	€0
------------	---	----	---	---	---	----