

Incident INCI015170 for Dublin Waste to Energy Licence (W0232-01)

Notification No: INCI015170

Submitted: 19/09/2018 13:51

Licensee Details

First Name:

Mark

Surname:

Heffernan

Address 1:

Pidgeon House Road

Address 2:

Ringsend

Town:

County:

Phone:

0863860942

Alternate phone:

Details

Description of Incident:

During Testing and Commissioning, the furnace temperature dropped below 850oC on Line 2 for 24 mins at 23:52hrs on 18 September 2018.

Incident Category:

Category 1

Approximate Start of Incident:

18/09/2018 23:52

First Noticed:

19/09/2018 23:53

Still Ongoing:

No

End Date:

19/09/2018 00:16

New or Recurring Incident:

New

Incident Nature:

Other

Impact of Incident on Environment:

All air pollution control units were operational at the time of this incident. No pollution caused as daily CEMS report compliant.

Uncontrolled Release to Receptors:

No
uncontrolled
release

Details of any Vulnerable Receptors:

n/a

Likely Cause:

Plant or equipment breakdown (Not at WWTP)

Incident Location

Discharge Point:

No

During Testing and Commissioning, the furnace temperature dropped below 850oC on Line 2 for 24 mins at 23:52hrs on 18 September 2018.

Communication

Informed by Telephone: Yes

Informed Date: 19/09/2018 05:33

Informed Staff Member: Afterhours phone line

Informed Contact Details: 0539160600

Other Communications:

Additional Details

Activity in Process at time of incident:

During Testing and Commissioning, the furnace temperature dropped below 850oC on Line 2 for 24 mins at 23:52hrs on 18 September 2018.

Corrective Actions Taken:

Action	Name	Date
investigation pending		26/09/2018 14:00

Preventive Actions to be Taken:

Action	Target Date
Investigation pending	26/09/2018 00:00

Likelihood of Recurrence: Low

Other Relevant Information

Close report and Daily CEMS file to follow